

子局	項目 No.	項目	機器番号 (TAGNO.)	現 場		中 央												備 考
				計測	変換	入出力点数		制 御		グラパネ		C R T		印字記録		警 報		
入力	出力	入切	出切	計測	制御	状態	故障	計測	計測	計測	計測	計測	計測	計測	計測		計測	計測
	181	コンデンサコンタクト	MCTT	○	○			9										
	182	コンデンサ 自動・手動		○	○													
	183	コンデンサ 故障		○				1										ガス圧異常
	184																	
	185	所変1次負荷開閉器	LBS	○	○			1										
	186	同上PF断		○				1										
	187	所変温度	DT	○				1										
	188	所変過負荷	TH	○				2										
	189	所変2次低圧地絡	LGR	○				1										
	190	所変(一括)MCB断	MCB	○				2										
	191																	
	192																	
	193	操作場所 中央・現場		○				1										
	194																	
	195																	
	196																	
	197																	
	198																	
	199																	
	200																	
管理棟	201	受電断路器	89R	○	○			1										
	202	受電遮断器	52R	○	○			1	1									
	203	受電不足電圧	UVR	○				1										
	204	受電過電流	OCR	○				1										
	205																	
	206																	
	207	動(灯)TR負荷開閉器	LBS	○	○			3										
	208	同上PF断		○				3										
	209	動(灯)TR温度	DT	○				3										
	210	動(灯)TR過負荷	TH	○				3										
	211	動(灯)TR低圧地絡	LGR	○				3										
	212	動(灯)変TR MCB断(一括)	MCB	○				3										
	213	コンデンサコンタクト	88C	○	○													
	214	コンデンサ故障		○				1										
	215																	
	216																	
	217																	
	218																	
	219																	
	220																	
メンテナンス	221	動(灯)TR負荷開閉器	LBS	○	○			2										
	222	同上PF断		○				2										
	223	動(灯)TR温度	DT	○				2										
	224	動(灯)TR過負荷	TH	○				2										
	225	動(灯)TR低圧地絡	LGR	○				2										
	226	動(灯)変TR MCB断(一括)	MCB	○				2										
	227																	
	228																	
	229																	
	230																	
	231																	
	232																	
	233																	
	234																	
	235																	
	236																	
	237																	
	238																	
	239																	
	240																	

